000100

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RAY KEY DATE 10-18-83 PERMIT NO.

PHONE: Business Home

LOCATION Buffalo Shoals Rd west - T.L. on Davidson Rd., then T.R. on 1st st. (149E) - 3rd house on (R).

SUBDIVISION NAME S. R. No.

LOT NO. SECTION OR BLOCK NO.

House ( ) Mobile Home ( ) Business ( ) Other ADDITION OF GARAGE BATHHOUSE COMBINATION.

No. Bedrooms NO No. Bathrooms 1+2 SINKS

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes ( ) No (✓)

Site Suitable Yes (✓) No ( )

Lot Area Ample


Character & Porosity of Soil Prov. Suitable

Percolation Rate 4gal/sq. ft.

Topography 2-6%

Depth to Water Table 10'+

Rock or other impervious formations none observed.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brewer

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brewer

EXISTING SYSTEM CHECKED BY: DATE 10-18-83

DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold