DIVISION OF ENVIRONMENTAL HEALTH:
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mtn Creek / Sean Ellis APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 4-2-03
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 360gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 4 Dawkson Woods PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	6%	0-7	wk sbk brnsdl	fr sss p					.3
		7-36	SBK RC	fr sp sap					
		36-45 (B-C)	wk f sbk yr cl	fr sbsp common mi sap					
2		0-22	wk f sbk rbrn cl	fr sp sap	few common mi sap few y brn mottles				.3
		22-47	wk f sbk brnk yr cl	fi fr sss p					
3		0-20	m f sbk rbrn cl	fr sp sap					.3
		20-43 (B-C)	wk f sbk yr cl	fr sss p	common mi sap				
4	4.5.03	0-33	m f sbk rbrn cl	fr sss p sap					.25
		33-42	wk f brnk yr c	fi fr sp sap					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	PM 25% Red	LPP 25-50% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DRT
OTHER(S) PRESENT: _____