IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR PHAM's MHP DATE 11-20-90 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Ridge Trailer Court on HWY 21 just before Davidson Rd. Entrance - 3rd Lot on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 12 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other Repair


No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes	( )	No	( )
Auto. Dishwasher	Yes	( )	No	( )
Auto. Wash. Machine	Yes	( )	No	(✓)
Site Suitable	Yes	(✓)	No	( )

Character & Porosity of Soil _____
Percolation Rate _____
Topography Repair
Depth to Water Table _____
Rock or other impervious formations _____

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 540 Lines Ft. 180
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Forest Shuford

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Took owner 4 new lids installed. All lids buried intact & new dist. box installed. Checked it & drain lines checked because they are underneath the mobile home.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 11-30-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold