Mayberry-
Blvr

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Brittian Lumber Co. DATE 10/19/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd to Bostian Hts. T.R. 1st dirt Rd - T.L. 1st. Rd. House on Rt. Below Travis apartments S. R. No. _____

SUBDIVISION NAME Bostian Hts. LOT NO. 17 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 sq ft. +


Character & Porosity of Soil Cecil Clay loam

Percolation Rate _____

Topography Slight Slope

Depth to Water Table Low

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Wes Lytton

IMPROVEMENTS PERMIT BY _____

COMMENTS: Downspouts and all surface water should be diverted away from septic Tank & lines. Extra dist to be put over at last turn.

CERTIFICATE OF COMPLETION BY E. O. Stevenson DATE 10/14/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold