IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. F. Travis DATE 12-19-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Out Buffalo Shoals Road - T. R. Just Past Airport Rd Then T.L. on Rd # 1416. Apt. House on R. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other APT. House

Each System
No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit	Yes (X)	No ( )	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	No Perk Test
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Slope to Back
Site Suitable	Yes ( )	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area _____



Plot of System

Each System
Size of Tank 1200 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1250 Linear Ft. 500
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public ( )

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lines are very deep. This layout made and Approved By Mr R. W. Johnson. Building started Prior to Sept 1, 1973.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 2-11-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold