34757

10235.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 6E-12-A-79

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR TRI-SOUTH CONST. DATE 12-28-82 PERMIT NO. B14.

PHONE: Business _____ Home _____

LOCATION Hwy 21 N. of Buffalo Creek Rd. - T.L. on 1st Parker Lago St. - T.L. on 1st St. West - 300 yards on left S. R. No. _____

SUBDIVISION NAME LAKEWOOD ESTATES. LOT NO. 74. SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 acre.

Character & Porosity of Soil Sandy Loam Suitable.


Percolation Rate 1" per 5 min.

Topography Level

Depth to Water Table 12+

Rock or other impervious formations None observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field: No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12

Water Supply: Individual ( ) Public (✓)

Installed by Claffin Farms.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-28-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold