03849

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RONNIE DUKE DATE 1-30-86. PERMIT NO.

PHONE: Business Home

LOCATION Buffalo Shoals Rd. west - T.R. on Airport Rd. - go 1/4 mi. - T.R. into dev. 4th lot on left


SUBDIVISION NAME DEERFIELD ESTATES LOT NO. 4 SECTION OR BLOCK NO. S. R. No.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	5 gal/sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 1 1/4 acre±			Rock or other impervious formations	none

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Rogers & Barry Sigmon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Do not drive or park over S.T. system.

CERTIFICATE OF COMPLETION BY ~~Steve Brown~~

EXISTING SYSTEM CHECKED BY: _____ DATE 1-30-86.

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold