01589

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frederick Dunn DATE 06-28-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd, T.R. on Airport Rd, 1/4 mile on (R) (7th lot on left.

S. R. No. _____

SUBDIVISION NAME Deerfield Estates LOT NO. 7 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 1 acre +

Character & Porosity of Soil Class III


Percolation Rate 0,5 gal 1+12 Hay

Topography 2-6% Slope

Depth to Water Table 101+

Rock or other impervious formations scattered Rock

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

Installed by AAA-Roger Seymour

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Upper line 5' deep.

CERTIFICATE OF COMPLETION BY Jerry D. Pierce DATE 06-28-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold