IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR RODNEY BARFIELD DATE 6-1-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. west - T.R. on Airport Rd. - 1/8 mi. on (R).


S. R. No. _____

SUBDIVISION NAME DEERFIELD ESTATES LOT NO. 42 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1-2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev. Suitable	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	.5gal/sq.ft.	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	104	
Lot Area 1 acre			Rock or other impervious formations	none observed.	



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-1-84.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold