IREDELL COUNTY HEALTH DEPARTMENT

02087 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 11am.
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Geoffrey Moore DATE 9-19-84 PERMIT NO.

PHONE: Business Home

LOCATION Duff Stns. N. west - TR Airpt. Rd. - go 3/8 mi. - TR in Deerfield Est., 1st street on rt - end street on left. S. R. No.

SUBDIVISION NAME Deerfield Est. LOT NO. 24 SECTION OR BLOCK NO.


Dbl. wide

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2-3 No. Bathrooms 1-2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate
Auto. Wash. Machine	Yes (✓)	No ( )	Topography
Site Suitable	Yes (✓)	No ( )	Depth to Water Table
Lot Area Ample			Rock or other impervious formations

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 720' Linear Ft. 240'
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by D. Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: PVC pipe to all drainlines ✓
Do not drive over any part of system.

CERTIFICATE OF COMPLETION BY Charles D. Gindler, R.S. DATE 9-19-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold