11699.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

DATE 2-26-90 PERMIT NO 6E-16.

OWNER OR CONTRACTOR ROGER KISER

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. west T.R. on Airport Rd. go 1/8 mi. T.R. into dev. T.R. on 1st. to Fenton Ct. S. R. No. _____

SUBDIVISION NAME DEERFIELD ESTATES LOT NO. 23 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Ample.

Character & Porosity of Soil Prov. Suitable

Percolation Rate See sep. sh.

Topography Level

Depth to Water Table 60"+

Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1000 Gals.


Nitrification Field:

No. of Lines 3

Sq. Ft. 210 Linear Ft. 240

Depth of Stone in Lines 1'

Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY: Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY: Steve Brown DATE 2-16-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold