IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob Kestler DATE 3/26/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Out Buffalo Shoals Rd to Bostian Hts. T.L. 1st Rd past Prey Rd #1337. Last house on L. at Curve S. R. No. _____

SUBDIVISION NAME Bostian Heights LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes	( )	No	( )
Auto. Dishwasher	Yes	( )	No	( )
Auto. Wash. Machine	Yes	( )	No	( )
Site Suitable	Yes	( )	No	( )

Lot Area _____

Character & Porosity of Soil _____
Percolation Rate _____
Topography Repair
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank Repair Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold