DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ____ OF ____

PROPERTY I.D.#: ____

DATE: ____

COUNTY: ____

LOT #5

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: CRIS DAVIDSON

ADDRESS: ____

OWNER ___ AGENT: ___ PHONE: ____

APPLICATION DATE: ____ DATE EVALUATED 9-5-95

PROPOSED FACILITY: ____

LOCATION OF SITE: ____

PROPERTY SIZE: ____

WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	B-10%	0-4"	l	gr				.1942 Wetness Cond. - S
	L	4"-36"	cl (fill - old stump hole)					.1943 Depth/.1956 Sapr. - NA
		36"-48"	c	sbk		relic mottling		.1944 Restrictive Hori. - NA
								.1948 Profile Class. - PS
								Profile LTAR - .3
2	B-10%	0-3"	l	gr				.1942 Wetness Cond. - S
	L	3"-48"	c	sbk		relic mottling		.1943 Depth/.1956 Sapr. - NA
								.1944 Restrictive Hori. - NA
								.1948 Profile Class. - PS
								Profile LTAR - .3
3	B-10%	0-5"	l	gr				.1942 Wetness Cond. - S
	L	5"-48"	c	sbk		relic mottling		.1943 Depth/.1956 Sapr. - NA
								.1944 Restrictive Hori. - NA
								.1948 Profile Class. - PS
								Profile LTAR - .3
4	B-10%	0-5"	l	gr	1:1			.1942 Wetness Cond. - S
	L	5"-28"	c	sbk	1:1	relic mottling		.1943 Depth/.1956 Sapr. - NA
		28"-48"	c	sbk	1:1			.1944 Restrictive Hori. - NA
								.1948 Profile Class. - PS
								Profile LTAR - .3

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) ____ SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE ____ LONG-TERM ACCEPTANCE RATE(S) .3 gpd/ft²

EVALUATED BY: Michael P. Dennis OTHER(S) PRESENT: Brad Stallard, J.C. Moore

COMMENTS: ____