DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:_____
DATE:_____
COUNTY:_____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Chris Davidson OWNER__AGENT:__PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED_____
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 4 Ravenwood
WATER SUPPLY: On-site Well____ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	~~ess~~	0 to 6	SL	GR				.1942 Wetness Cond. - N/A
		6 to 22	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	linear	22 to	C	weak SBK	1:1	Relic	mottling	.1944 Restrictive Hori. - N/A
	8 1270							.1948 Profile Class. - PS
								Profile LTAR - .25
2		0 to 1	Litter Layer					.1942 Wetness Cond. - N/A
	linear	1 to 48	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	10 70	48 to 48	Saprolite		1:1			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
3		0 to 6	SL	GR				.1942 Wetness Cond. - N/A
	linear	6 to 48	~~SL~~ C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	10 70							.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) V/R OTHER FACTORS (.1946)_____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .3

EVALUATED BY: P. C. Moore OTHER(S) PRESENT: Chris Davidson

COMMENTS:_____

0 0 0 4 0