IREDELL COUNTY HEALTH DEPARTMENT

01737

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BETTY CALDWELL DATE 7-27-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. west, T.R. on Airport Rd. - T.R. into Deerfield Estates Keep straight around curve - MH on left. S. R. No. _____


SUBDIVISION NAME DEERFIELD ESTATES LOT NO. 18 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Prev. Suitable
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	5 min/1 in.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area 2.65 acres			Rock or other impervious formations	none

_____ Basement with Plumbing _____ Basement without Plumbing (✓) No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Terry L. Pierce

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-27-84.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold