HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Chris Davidson OWNER:_AGENT:_ PHONE:
ADDRESS: APPLICATION DATE:_____DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE: 1 1/2 acres
LOCATION OF SITE: Lot 11 Ravenswood
WATER SUPPLY: On-Site Well____Comm. Well___Public___Other_____EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear 12%	0 to 8	L GR		PS	PS	PS	PS	.3
		8 to 48	C SBK	SEAP Firm to Fr					
2	Linear 12%	0 to 8	L GR		PS	PS	PS	PS	.3
		8 to 24	C SBK	SEAP Fi to Fr.					
		24 to 48	CL WSBK	SEAP FR					
3									
4									
5									

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948):_____SITE LONG-TERM ACCEPTANCE RATE:
EVALUATED BY: L. Emoore OTHER(S) PRESENT: Chris Davidson
COMMENTS:

003178