HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Dennis A. Hutchens OWNER: __ AGENT: __ PHONE: _____
ADDRESS: _____ APPLICATION DATE _____ DATE EVALUATED: 11-17-93
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE: _____

LOCATION OF SITE: Island Ford Rd
WATER SUPPLY: On-Site Well ✓ Comm. Well __ Public __ Other _____ EVAL. METHOD: Auger Boring ✓ Pit __ Cut __

PROFILE #	.1940 LANDSCAPE POS / SLOPE %	HORIZON DEPTH (")	(.1941) (a) TEXTURE	(b) STRUCTURE	(c) MOTTLES		
1	20-24% L	0-8"	cl	gr	1:1	vfr	.1942 WETNESS CONDITION - P.S.
		8-45"	C	sbk	1:1	fr	.1943/.1955 SAPROLITE - NA
							.1944 RESTRICTIVE HORIZON - NA
							.1945 PROFILE CLASSIFICATION - P.S.
							PROFILE LTAR - .35
2	20-24% L	0-6"	cl	gr	1:1	vfr	.1942 WETNESS CONDITION - P.S
		6"-48"	C	sbk	1:1	fr	.1943/.1955 SAPROLITE - NA
							.1944 RESTRICTIVE HORIZON - NA
							.1945 PROFILE CLASSIFICATION - P.S.
							PROFILE LTAR - .35
3	20-24% L	0-7"	cl	gr	1:1	vfr	.1942 WETNESS CONDITION - P.S
		7"-45"	C	sbk	1:1	fr	.1943/.1955 SAPROLITE - NA
							.1944 RESTRICTIVE HORIZON - NA
							.1945 PROFILE CLASSIFICATION - P.S.
							PROFILE LTAR - .35
4							.1942 WETNESS CONDITION -
							.1943/.1955 SAPROLITE -
							.1944 RESTRICTIVE HORIZON -
							.1945 PROFILE CLASSIFICATION -
							PROFILE LTAR -
5							.1942 WETNESS CONDITION -
							.1943/.1955 SAPROLITE -
							.1944 RESTRICTIVE HORIZON -
							.1945 PROFILE CLASSIFICATION -
							PROFILE LTAR -

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1945): P.S SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: Michael A. Dennis OTHER(S) PRESENT: Dennis Hutchens
COMMENTS: _____

DRAFT