FHA

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR BILL ELLENBURG DATE 8-16-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64-70 west past Harley-Davidson, Place, T.L. on Mineberry Rd. - go to end of street at cultisak. S. R. No. _____


SUBDIVISION NAME Hickory Hills LOT NO. 13 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1.5

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Prov. Suitable
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 5 gal/sq. ft.
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10'+
Lot Area Ample			Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field: 3

No. of Lines _____

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Robert Hefe

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pipe downspouts away from S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____ DATE 8-16-83

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold