01265

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

01265

OWNER OR CONTRACTOR Ricky Souther DATE 06-22-84 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W past Airport Rd, T.L. on Wineberry Lane, 4th house on right S. R. No. _____

SUBDIVISION NAME Hickory Hills LOT NO. 18 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 155'X200'

Character & Porosity of Soil Clay, Suitable
Percolation Rate 0.5 gal/ft²/day
Topography 2-6% Slope
Depth to Water Table 70+
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Cline-Gillian

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Change in original lay out (03-16-84) from 3 lines 80' long to 2 lines 120' long

CERTIFICATE OF COMPLETION BY Jerry L Rice DATE 06-22-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold