02378

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR GARY FOX DATE 2-14-85. PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64-70 west past Harley Davidson Place - T.L. on Winebarry Lane - halfway up hill on left. S. R. No. 1

SUBDIVISION NAME HICKORY HILLS DEV. LOT NO. 8 SECTION OR BLOCK NO. _____

House (4) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (4)
Auto. Dishwasher Yes ( ) No (4)
Auto. Wash. Machine Yes (4) No ( )
Site Suitable Yes (4) No ( )

Lot Area 90' x 210'

Character & Porosity of Soil Prev. Suitable
Percolation Rate 5gal./sq. ft.
Topography 2-6%
Depth to Water Table 10'+
Rock or other impervious formations none observed.

_____ Basement with Plumbing 4 Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (4)

Installed by Donald Lackey

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 2-14-85.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold