02694

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JACK + BETTY HITTLE DATE 5-23-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64-70 west past Harley Davidson Place - T.L. on Mineberry Lane - 300 yards on left. _____ S. R. No. ✓

SUBDIVISION NAME HICKORY HILLS DEV. LOT NO. 6 SECTION OR BLOCK NO. _____

House (4) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (4)	
Auto. Dishwasher	Yes (4)	No ( )	
Auto. Wash. Machine	Yes (4)	No ( )	
Site Suitable	Yes (4)	No ( )	

Lot Area 90' X 210'

Character & Porosity of Soil Pgor. Suitable


Percolation Rate .5 gal./sq. ft.

Topography 2-6%

Depth to Water Table 11+

Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 240 Linear Ft. 120
Depth of Stone in Lines 12" SAND

Water Supply: Individual ( ) UNDER
Public (4) PANELS

120' of 16" T+J PANELS.

Installed by Eddie Yountz

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pipe off both front downspouts from gutters away from septic tank system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-23-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold