IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gilles J. Metivier DATE 12/28/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 W. Cross Third Creek - T.L. into Sub-Division - House on L. S. R. No. _____

SUBDIVISION NAME Hickory Hills LOT NO. 4 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20,000 sq ft

Character & Porosity of Soil Red clay
Percolation Rate _____
Topography Slope to N. Side
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: All surface water should be diverted away from Tank + lines. This system Put in in wet weather

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/28/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold