IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JAMES SLOAN DATE 1-12-84 PERMIT NO.

PHONE: Business Home

LOCATION 64-70 west, T.R. on Westminister Drive, then T.L. into Westover Dev. at 1st entrance - go to bottom of hill + around curve - house on left


SUBDIVISION NAME WESTOVER LOT NO. 22 SECTION OR BLOCK NO. S. R. No.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1.0

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area Ample

Character & Porosity of Soil Prev. Suitable
Percolation Rate .5 gal/sq. ft.
Topography 2-6%
Depth to Water Table 10+
Rock or other impervious formations none observed.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by Tommy Cantrell

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS:

CERTIFICATE OF COMPLETION BY Steve Brown DATE 1-12-84
EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold