IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR HOPE BROS. - FHA DATE 1-7-82 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Westminster Rd. - 9764 - 7th west - T.L. into Westover Dev., go on around sharp curve top hill house on (R), _____ S. R. No. _____

SUBDIVISION NAME Westover LOT NO. 80 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 1.5

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil sandy clay
Percolation Rate 5 gal/sq. ft.
Topography 2-6%
Depth to Water Table 104
Rock or other impervious formations none observed.

Lot Area Ample

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bros.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pipe off downspouts from gutters away from S.T. system & moved at least 12" extra soil under solid pipe across driveway.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 1-7-82

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold