08162

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR KENNETH HOPE DATE 10-14-88 PERMIT NO. 10 D.

PHONE: Business _____ Home _____

LOCATION Westinister Drive off Hwy 64-70W T.L. into Westover Dev. go down hill 4 up around Curve - T.R. on Hollywood Dr. - 1st house on L. S. R. No. _____

SUBDIVISION NAME WESTOVER DEV. LOT NO. 81 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area Ample.

Character & Porosity of Soil Grav. Suitable.


Percolation Rate 1 gal. / sq. ft.

Topography 2 to 10%

Depth to Water Table 10'+

Rock or other impervious formations None Observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement




Size of Tank 1000 Gals.

Nitrification Field: No. of Lines 3 210

Sq. Ft. _____ Linear Ft.

Depth of Stone in Lines 12"

Water Supply: Individual ( ) Public (✓)

Installed by Hope Bros.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-14-88.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold