IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Byron DeSoto DATE 5/29/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Westover

S. R. No. _____


SUBDIVISION NAME Westover Addition LOT NO. 85 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 15000 +

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography Slope Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Byron DeSoto + J. C. Back Hoe Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lines are shallow at second turn and at end of lines. Extra dirt to be put in this area. 12" to 16" — Tank is Set. Downspouts & surface water to be diverted away.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5/29/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold