Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 OF 1
PIN #: 4724-16-8432
Lot #: 101
Permit #: 211610
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: ROBERT GLEAVES
Applicant: SAME
Address: 709 WELLWOOD DR.
Date Evaluated: 7/10/2015
Proposed Facility: SFR REPAIR
Design Flow (.1949) 360
Property Size:
Location of Site: WESTOVER LOT 101
Property Recorded: YES
Water Supply: [X] Public [ ] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [X] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 1941 Structure/ Texture	SOIL MORPHOLOGY .1941 1941 Consistence Mineralogy	b PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
AB 1	LINEAR 10%	0-29	RC,M,SBK	SS	NA	48"	NA	48"+	.3
		29-48	RCL,W,SBK	SS					
PIT 2	LINEAR 10%	0-35	RC,M,SBK	SS	NA	48"	FEW INC @ 35-48"	48"+	.3
		35-48	SCL,M,SBK	SS					
PIT 3	LINEAR 10%	0-17	RC,M,SBK	SS	NA	48"	NA	48"+	.3
		17-48	RCL,M,SBK	SS					
PIT 4	LINEAR 10%	0-24	RC,M,SBK	SS	NA	48"	NA	48"+	.3
		24-48	RCL,M,SBK	SS					

Description	Initial System	Repair System
Available Space (.1945)		PS
System Type(s)		G-PANEL BLOCK
Site LTAR		.3

Other Factors (.1946):
Soil Evaluation By: BEN ALDRIDGE
Others Present: KEVIN POWELL, KEVIN BOWELS
Site Classification (.1948): PS
Site Evaluation By: BEN ALDRIDGE
Others Present: KEVIN POWELL, KEVIN BOWELS