IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Statesville – Mooresville Home Bldrs. assn. DATE 5/8/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION _____

_____ S. R. No. _____

SUBDIVISION NAME Westover Addition LOT NO. 5 SECTION OR BLOCK NO. _____


House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (+)	
Auto. Dishwasher	Yes (+)	No ( )	
Auto. Wash. Machine	Yes (+)	No ( )	
Site Suitable	Yes (+)	No ( )	

Lot Area 15000 sq ft

Character & Porosity of Soil Prof Suitable
Percolation Rate _____
Topography 2-6% Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (+)

Installed by Wes Lytton

IMPROVEMENTS PERMIT BY _____

COMMENTS: All surface water possible to be diverted away from septic tank + lines. Downspout at back corner next to tank + lines to be piped away.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5/8/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold