IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JERRY BENFIELD DATE 4-27-88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64-70 West-T.R. on Westmoreland Dr.-T.L. on Dorsey Dr., go to end at cul-de-sac. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 1.5

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Good
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Rolling
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none observed


Lot Area Ample

_____ Basement with Plumbing _____ Basement without Plumbing (✓) No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 120 Linear Ft. 240
Depth of Stone in Lines 24"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by Dennis Gallimore

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Kelly Sleeks, R.E.

COMMENTS: Washing machine left hooked to old system.

CERTIFICATE OF COMPLETION BY Steve Brewer DATE 4-27-88.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold