Jeff Horne
Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Daly DATE 11-2-76 PERMIT NO.

PHONE: Business Home

LOCATION House on North East Corner of Crestridge Drive and Westover Road

SUBDIVISION NAME Westover LOT NO. 48 SECTION OR BLOCK NO. S. R. No.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 17,000 sq ft

Character & Porosity of Soil Cecil Clay.
Percolation Rate
Topography Slight Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY

COMMENTS: All downspouts from house and surface water should be diverted away from Tank & Lines. Water line to come in around septic Tank line and not across them.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/3/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold