IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR LARRY MOOSE DATE 7-6-88 PERMIT NO.

PHONE: Business Home

LOCATION: Hwy 64-70W-T.R on Westminister Drive-T.L. on Brandy Lane, 2nd house on left. S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other Repair.


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No (✓)
Site Suitable	Yes (✓)	No ( )

Lot Area Ample

Character & Porosity of Soil
Percolation Rate
Topography Existing
Depth to Water Table
Rock or other impervious formations

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank EXISTING Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 450 Linear Ft. 150
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Tommy Reins

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Kelly Sheets R.S.

COMMENTS: Recommend pumping septic tank if not pumped in last 5 years. New tee to be put in tank for new line.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 7-6-88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold