DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4724389384
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Larry Stroud — APPLICATION DATE 4-15-13
ADDRESS: 412 Westminster Dr — DATE EVALUATED: 4-26-13
PROPOSED FACILITY: 2 BR Repair — PROPOSED DESIGN FLOW (.1949): _____ — PROPERTY SIZE: 1.04 acres
LOCATION OF SITE: 412 Westminster Dr — PROPERTY RECORDED: yes
WATER SUPPLY: • Private • Public • Well • Spring • Other N/A
EVALUATION METHOD: • Auger Boring • Pit • Cut — TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4% L	0-22	C micaceous SiCL	Fr Mod SE	48"	48"	48"	48"	PS 0.3
		22-48	CL micaceous WSBK	Fr Mod SE					
2	3% L	0-20	C micaceous SiCL	Fr Mod SE	48"	48"	48"	48"	PS 0.3
		20-48	CL micaceous WSBK	Fr Mod SE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		III
Site LTAR		0.3

OTHER FACTORS (.1946): N/A
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Justin Henderson
OTHER(S) PRESENT: Larry Stroud

COMMENTS: N/A