IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR HOMER BASS DATE 6-17-92. PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 70 W - T.R. on street to Bill's Welding Shop - go by shop to Stop sign & go straight across rd - 1st house on left.


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S.R. No. _____

House ☑ Mobile Home ☐ Business ☐ Other Repair.

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ☐	No ☐	Soil Characteristics _____
Auto. Dishwasher	Yes ☐	No ☐	Application Rate _____
Auto. Wash. Machine	Yes ☐	No ☐	Topography _____
Lot Area Ample.			Depth to Water Table Repair.
			Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank EXISTING. Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 12"
Water Supply: Individual ☑
Public ☐

Installed by Barry Digman

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Steve Brown

COMMENTS New tee installed + tank pumped. old drain lines abandoned, but new lines contact old drainfield at end.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-17-92.

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold