IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date Nov 15 1949

Owner Brittain Lumber Co. Address Statesville

Tenant _____ Address _____

Installed by E. W. Ostwalt Address Trouman

Location of Property Hickory Rd. on R/W this side of Catawba Iron: #2 house

Kind of Tank Black Capacity 900 Length of trench 800 ft.


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection Nov. 15 1949 Approved (✓) Disapproved ( )

Remarks: 2 houses on one line Tank 10x7x6

First five feet of line from outlet should be of cast iron soil pipe.



James E. Brown
Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.