IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 81905 PIN# 4724 56 7198 DATE 3-26-99

OWNER OR CONTRACTOR CHURCH of GOD of PROPHECY PHONE: Business 878-2468 Home 878-0386

ADDRESS 504 BRISTOL DRIVE, STATESVILLE NC 28677

LOCATION US 70 W, TR BRISTOL DRIVE, CHURCH ON LEFT AT BOX # 504

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA LIMITED SITE CLASS PS DESIGN FLOW 675 L.T.A.R. 0.30 GPD/FT²

Septic Tank: 1500 Gallons; STB 1011 Date 5-19-99

GREASE TRAP Tank: 1000 Gallons; PT 358 Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet REQ'D 2250 Linear Feet 3127

No Lines FOUR (4) Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth SAND 6"

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: 25% REDUCTION SYSTEM

Repair System Description: PRESS PUMP-FED

Maintenance Agreement Required: ☐ Yes ☑ No

☐ House/Mod. Home No. Bedrooms _____

☐ Mobile Home No. Bathrooms _____

☐ Business No. Employees _____

☑ Other CHURCH W/ DAYCARE @ 25 PERSONS

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public WELL ☐ Community

Comments/Conditions: ① Pump-Out EXISTING SEPTIC TANK & REMOVE OR CRUSH & FILL WITH CLAY DIRT ② INSTALL NEW S.T. AS SHOWN PASSING OLD LINES FIRST W/ NEW DIST. BOX, ③ INSTALL 25% REDUCTION SYSTEM USING, FIFTY-TWO (52) CHAMBERS OR THIRTY-TWO (32) H.D.S. SECTIONS ④ KEEP SYSTEM MINIMUM 100 FEET FROM WELL ⑤ SEE ATTACHED SHEET FOR INITAL SITE SKETCH ⑥ PERMIT REVISED 6-19-99 TO INCLUDE 1000 GALLON GREASE TRAP

Comments Conditions: SYSTEM SIZED TO ACCOMODATE SANCTUARY WITH 100 PERSON SEATING CAPACITY PLUS DAYCARE WITH 25 PERSONS (CHILDREN AND STAFF)

INITIAL SITE SKETCH

AS BUILT SKETCH

* Note able to use old tank for grease Trap

Installed as shown

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit -- not to exceed sixty months.

Signed: Bill Long date 3/29/99 Installed by: Donald Lackey

Improvement Permit by: STEVE HEDRICK date 3-26-99 Operation Permit by: Mary Cox KS date 7-1-99

Authorization to Construct by: STEVE HEDRICK date 3-26-99 Existing System Inspection by: _____ date _____

HEALTH DEPT COPY WHITE OWNER COPY (FINAL) YELLOW OWNER COPY (INITIAL) PINK