IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mark Stevenson DATE 04-23-86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 506 Holly St. - off Greencrest Dr. which is off Bristol Dr. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes ( )	No ( )	Topography	Repair
Site Suitable	Yes ( )	No ( )	Depth to Water Table	
			Rock or other impervious formations	

Lot Area Limited

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. 40'
Depth of Stone in Lines _____

Water Supply: Individual ( )
Public ( )

Installed 49 ton subsurface trench

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pumped tank, set new tee to feed subsurface trench first. Trench contains 49 tons of stone w/ 40' flexible drain line

CERTIFICATE OF COMPLETION BY Jerry L Price DATE 04-23-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold