DIVISION OF ENVIRONMENTAL HEALTH

COUNTY:

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: Olde Towne MH OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Lot 8 Sherrill Estates phase 2
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | 890 linear | 0 to 36 | C SBK | SEAP Fi | PS | PS | PS | N/A | .3 |
| | | 36 to 48 | SCL WSBK | SEAP FR | | | | | |
| 2 | 790 linear | 0 to 48 | C SBK | SEAP FR | PS | PS | PS | N/A | .3 |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | | | | | | | | |

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: F.C. Moore OTHER(S) PRESENT: Steve Hetrick
COMMENTS: Fillet area on back side of lot

003160