IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR New Hope FreeWill DATE 10-24-73 PERMIT NO. _____

PHONE: Business Baptist Home Church

LOCATION Go Out Park Drive to Bristol Road T.R. Church on R- 2200 Block S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Church

No. Bedrooms _____ No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes ( ) No ( )
Lot Area 70X200

Character & Porosity of Soil Red Clay
Percolation Rate No Perc Test
Topography Slightly sloping Toward Back Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines _____
Water Supply: Individual ( )
Public (✓)

Installed by N. Iredell Septic Tank Co.

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Church has 35 Members. Original layout had to be changed due to location of Gas lines Tank & Lines are Deep.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12-15-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold