DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Thomas Ramsey Sr APPLICANT: Same
ADDRESS: 217 Bristol Rd Statesville NC APPLICATION DATE: — DATE EVALUATED: 10/5/21
~~PROPOSED~~ FACILITY: 3BR Home Tenant PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: Yes
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed 4 @ 106'

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	Linear 10%	0-16	c	fi Sp SBK	16" SRX N/Y/M mx/c to 43"				3
		16-24	c w/sap	fi Sp					
		24-48	c/co	SSsp					
2	Linear	0-4	scl	fr	f.				1.5
		4-18	~~scl~~ c	fi					
		18-48	cl w/m						
3	Linear	0-2	sl	fr					3
		2-20	c	fi					
		20-48	c few sap	fi					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	15	
System Type(s)	Gravity Conv	
Site LTAR	.3	

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: BPH/JohnSon
OTHER(S) PRESENT: Thomas Ramsey Sr.