IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR BETTY BURNETT DATE 2-6-92. PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 2339 Craig St. - T.L. off Industrial Blvd. onto Wooten St. go to 1st st. on left - Corner House. S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other Repair.

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit Yes ☐ No ☐

Auto. Dishwasher Yes ☐ No ☐

Auto. Wash. Machine Yes ☐ No ☐

Lot Area Ample.

Soil Characteristics _____


Application Rate _____

Topography _____

Depth to Water Table Repair.

Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank EXISTING. Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 360 Linear Ft 120

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑

Installed by Barry Sigmon

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Steve Brown

COMMENTS New tee installed in tank. Existing dist. box used.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 2-6-92.

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold