# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. _____ DATE 1-30-97 TAX MAP NO. _____ Watershed: ☐ Yes ☒ No

OWNER OR CONTRACTOR Jerry Keller PHONE: Business 1-800 822 1212 Home 872-8723

ADDRESS 2325 Craig St Statesville NC 28677

LOCATION I-40 TL 90E TL Wooten TL Craig house on Rt

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA _____ SITE CLASS. 0/S DESIGN FLOW 240 L.T.A.R. 0.5

Septic Tank: 1000 New Gallons; STB 1070 Date 2-24-97

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet _____ Linear Feet _____

No Lines Bed 2 Trench Width 6Ft Max Trench Bottom Depth 36in Gravel Depth 18"

☐ New System ☒ Repair System Type: I ☒ III, IV, V, VI

System Description: _____

Repair System Description: Bed

Maintenance Agreement Required: ☐ Yes ☐ No

☐ House/Mod. Home No. Bedrooms 2

☐ Mobile Home No. Bathrooms 1

☐ Business No. Employees ____

☐ Other _____


☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☐ Community ☒ Public


Comments: E-line Existing tank before adding addition
Install New tank, Bed Repair 6x40 Ft, 18in gravel
Tie into old system if possible
(Line)

Comments:

INITIAL SITE SKETCH




AS CUILT SKETCH




I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance. Authorization to construct expires 5 yrs from issue date.

Signed: Richard Keller

Improvement Permit by: Mark Cox RS date 1-30-97

Authorization to Const. Existing system inspection by: Mark Cox RS date 1-30-97

Installed by: Betty Sigmon

Certificate of Completion by: _____ date _____

Operation Permit by: Mark Cox RS date 4-9-97

HEALTH DEPT COPY (WHITE) INSPECTION COPY (FINAL) GREEN OWNER COPY (FINAL) YELLOW INSPECTION COPY (INITIAL) PINK OWNER COPY (INITIAL) GOLD