REPAIR

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR LARRY HEDRICK DATE 5/14/93 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION INDUSTRIAL BOULEVARD WEST, TL CLINE STREET, ROAD TURNS (L) TWICE, HOUSE ON (L) AT #2240 CLINE STREET S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area LIMITED

Soil Characteristics EXISTING


Application Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank EXISTING Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑

Installed by AAA ENTERPRISE

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS

(1) TANK RECENTLY PUMPED-OUT

(2) NEW SANITARY 'TEE' INSTALLED

(3) TWO NEW D. BOXES INSTALLED AS SHOWN

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 5/19/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold