DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4715-98-6382.C

OWNER: DORIS WEST APPLICANT: RURAL AFFORDABLE HOUSING
ADDRESS: 218 WEST BROAD ST, STVL, NC APPLICATION DATE: 7-17-02 DATE EVALUATED: 8-7-02
PROPOSED FACILITY: 3BR S/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 173.48 ACRES
LOCATION OF SITE: NC 90 W, TR DEER RIDGE, BEAR (R) 2ND ON (L) PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	SLIGHT H 6%	0-48	SBK C	FR SEXP					PS 0.3
2	SLIGHT H 8%	0-48	SBK C	FR SEXP					PS 0.3
3	H 6%	0-48	SBK C	FR SEXP					PS 0.3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	I	I
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: TOMMY GILBERT, JENNIFER ?