INITIAL SYSTEM (Continued)

CHECK VALVE NEEDED:	No
PUMP REQUIREMENTS:	64.0 gpm at 13.8 feet of head. Use Hydromatic 1/2 horsepower SP50M1 pump, or Myers 1/2 horsepower WHR5-11C pump, or Zoeller 1/2 horsepower N137 pump, or Goulds 1/2 horsepower WE05-11H pump, Model #3885, or approved equal pump.
PUMP RUN TIME PER DOSE:	8.0 minutes
FLOAT LEVELS WITHIN DOSING TANK:	Pump "off" @ 19" above tank floor. Pump "on" @ 30" above tank floor. Alarm "on" @ 33" above tank floor.