IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR CAROLINA PETROLEUM DATE 3-10-81 PERMIT NO. —

PHONE: Business _____ Home _____

LOCATION Hwy 90 - access from Monticello School

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business (✓) Other Repair - system only designed for 15 employees and no more.

No. Bedrooms — No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil _____
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate _____
Auto. Wash. Machine	Yes ( )	No (✓)	Topography existing system
Site Suitable	Yes (✓)	No ( )	Depth to Water Table _____
			Rock or other impervious formations _____

Lot Area LIMITED

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 650 Linear Ft. 195
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Water line moved under office & gas line moved up against office. Well capped.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 3-10-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold