IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR WAKEFIELD BENTLEY DATE 6-16-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 West - house on left at corner of Kay Lane. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other New System installed - plot system attached.

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Poor Suitable.
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	5 gal. / g. ft.
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2-6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'
			Rock or other impervious formations	none observed.

Lot Area Ample

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 24"

Water Supply: Individual ( )
Public (✓)

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Solid pipe across driveway in one trench (PVC SCH 40). Old drain lines edged by new lines.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 6-16-87.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold