IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Hamm DATE 01-07-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 90 - T.R. (1st Rd) on Right above Monticello School at A+J Mini Mart go to Grayson MPH, to 2nd entrance, 7th trailer on (R) S. R. No. 1546

SUBDIVISION NAME Grayson MPH LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 1.5

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil _____

Percolation Rate _____


Topography Repair

Depth to Water Table _____

Rock or other impervious formations _____

Lot Area _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank Existing Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 300 Linear Ft. 100

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by AAA - Sigmon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Landscape to prevent surface water from standing on nitrification lines

CERTIFICATE OF COMPLETION BY Terry L Price DATE 01-07-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold