IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 38626
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12157

OWNER OR CONTRACTOR HERITAGE BLDG CO. DATE 1/10/91 PERMIT NO. 9D-A-55

PHONE: Business _____ Home _____

LOCATION 115N, TL OLD WILKESBORO RD, TL MARCELLO RD, TR MILLER FARM RD, TL PINEY OAKS ~ 1/8 MI ON (L) S. R. No. _____

SUBDIVISION NAME PINEY OAKS LOT NO. 34 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil PS
Percolation Rate .4 GPD/FT2
Topography 4-8% LS
Depth to Water Table >4'
Rock or other impervious formations NONE

Lot Area 1.022 AC -100% REPAIR AREA-

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement ACP 11/17/90



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by WES LYTTON

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 1/10/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold