12486.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR MAHAFFEY BROS. BLDRS. DATE 5-1-91 PERMIT NO. 91-13-A-10.

PHONE: Business _____ Home _____

LOCATION Hwy 90W-T.R. on Monticello Dr.-T.L. on Miller Farm Rd.-T.L. into Piney Oaks Dev.-½ mi. on R. S. R. No. _____

SUBDIVISION NAME PINEY OAKS DEV. LOT NO. 10. SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2


Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Prev. Suitable.
Percolation Rate 2-min/1 in. Topography Gent. Sq. ft.
Depth to Water Table 18"+ Rock or other impervious formations none observed.

Lot Area Ample.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900+ Lines Ft. 300+
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)



Plot of System

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Hedrick

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-1-91.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold