DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: David Gray
APPLICANT: Modular Housing Associated
ADDRESS: _____
APPLICATION DATE: _____
DATE EVALUATED: 8/29/01
PROPOSED FACILITY: 4BR/Cmd
PROPOSED DESIGN FLOW (.1949): 480
PROPERTY SIZE: _____
LOCATION OF SITE: _____
PROPERTY RECORDED: X
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	6% Linear	0-7	SL g	fr NSNP NEXP					PS .35
		7-48	Sc SBK	fi SS NO SEXP					
2	7% Linear	0-8	SL gr	fr NS NP NEXP					PS .35
		8-48	Sc SBK	fi SS NP NEXP					
3	10% Linear	0-9	SL gr	fr NS NP SEXP					PS .35
		9-48	Sc SBK	fi SS NP SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Red. Gravity	50% Reduction Trench
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Lehmann
OTHER(S) PRESENT: _____